



BRICK & MORTAR RESEARCH LABORATORY

A trading division of Sharp & Howells Pty Ltd ACN 004 782 996 ABN 26 004 782 996

NATA Accredited Laboratory No 658

FACTORY 2, 2 HORNE ST HOPPERS CROSSING VIC 3029 PH/FAX: (03) 9369 8018 MOB: 0419 592 838 EMAIL: bmr1@bigpond.com WEBSITE: bmr1.com.au

Page 1 of 2

TEST CERTIFICATE NO 7954

DATE: 14/6/11

EVALUATION OF BASALT

CLIENT: J & P Stone Imports
PO Box 577
Belmont Vic 3216

SAMPLE: Chinese basalt

SAMPLER: Client

RECEIVED: 17/5/11

DATE OF TESTING: 20 May to 9 June 2011

TEST

METHOD OF TEST

Determination of:

Resistance to salt attack

AS/NZS 4456.10-2003

NATA Accredited Laboratory Number 658

This document is issued in accordance with NATA's accreditation requirements. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.
Accredited for compliance with ISO/IEC 17025.



Stuart Errey
MRACI, C Chem
Manager

Test Certificate No 7954

14/6/11

RESISTANCE TO SALT ATTACK

Test solution: sodium sulfate
Test method: method A

Specimen no	1	2	3	4	5
Mass loss, %	0.01	0.01	0.01	0.01	0.01

Mean mass loss: 0.01 %.

COMPLIES with criterion (b) for the Exposure category.